



IECEX Certificate of Conformity

INTERNATIONAL ELECTROTECHNICAL COMMISSION IEC Certification Scheme for Explosive Atmospheres

for rules and details of the IECEx Scheme visit www.iecex.com

Certificate No.: IECEx IBE 12.0021 issue No.:1 Certificate history:
Issue No. 1 (2013-8-9)
Issue No. 0 (2012-9-19)

Status: **Current**

Date of Issue: **2013-08-09** Page 1 of 5

Applicant: **BARTEC GmbH**
Max-Eyth-Straße 16
97980 Bad Mergentheim
Germany

Electrical Apparatus: **RS485-Profibuscoupler, -repeater type 17-6583-3***/******
Optional accessory:

Type of Protection: **Intrinsic safety "ib"**

Marking: **[Ex ib Gb] IIC**
[Ex ib Db] IIIC


*Approved for issue on behalf of the IECEx
Certification Body:*

Prof. Dr. Tammo Redeker

Position:

Head of Certification Body

*Signature:
(for printed version)*



2013-08-09

Date:

1. This certificate and schedule may only be reproduced in full.
2. This certificate is not transferable and remains the property of the issuing body.
3. The Status and authenticity of this certificate may be verified by visiting the [Official IECEx Website](http://www.iecex.com).

Certificate issued by:

IBExU Institut für Sicherheitstechnik GmbH
Certification Body
Fuchsmühlenweg 7
09599 Freiberg
Germany



IECEx Certificate of Conformity

Certificate No.: IECEx IBE 12.0021

Date of Issue: 2013-08-09

Issue No.: 1

Page 2 of 5

Manufacturer: **BARTEC GmbH**
Max-Eyth-Straße 16
97980 Bad Mergentheim
Germany

Additional Manufacturing location
(s):

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEx Quality system requirements. This certificate is granted subject to the conditions as set out in IECEx Scheme Rules, IECEx 02 and Operational Documents as amended.

STANDARDS:

The electrical apparatus and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards:

IEC 60079-0 : 2011 Explosive atmospheres - Part 0: General requirements
Edition: 6.0

IEC 60079-11 : 2011 Explosive atmospheres - Part 11: Equipment protection by intrinsic safety "i"
Edition: 6.0

This Certificate does not indicate compliance with electrical safety and performance requirements other than those expressly included in the Standards listed above.

TEST & ASSESSMENT REPORTS:

A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in

Test Report:

[DE/IBE/ExTR12.0019/00](#)

[DE/IBE/ExTR12.0019/01](#)

Quality Assessment Report:

[DE/TUN/QAR06.0017/04](#)



IECEx Certificate of Conformity

Certificate No.: IECEx IBE 12.0021

Date of Issue: 2013-08-09

Issue No.: 1

Page 3 of 5

Schedule

EQUIPMENT:

Equipment and systems covered by this certificate are as follows:

The RS485-Profibus coupler / RS485-Profibus repeater are associated apparatus intended for the use outside of hazardous areas. The apparatus provides intrinsically safe circuits to be connected outside of hazardous areas with other apparatus located in hazardous areas of zone 1. The RS485-Profibus coupler / RS485-Profibus repeater may be used only outside of hazardous areas and only in a housing required for protection class IP20.

The PROFIBUS couplers and PROFIBUS repeaters are used for the separation or generation of new segments, converting the RS485 typical line structure into an open and flexible tree structure. Downstream stations can be coupled to and decoupled from the superior bus system in a non-reactive and break/short-circuit tolerant manner, even during running bus operation. The apparatus provides terminals for 1 Master and for 4 Slaves.

Type designation

RS485-Profibus Coupler	17-6583-3K**/****
RS485-Profibus Repeater	17-6583-3R**/****

CONDITIONS OF CERTIFICATION: NO



IECEx Certificate of Conformity

Certificate No.: IECEx IBE 12.0021

Date of Issue: 2013-08-09

Issue No.: 1

Page 4 of 5

EQUIPMENT(continued):

Technical data

Ambient temperature range
Degree of protection of the enclosure

-25 °C to 65 °C
IP 20

Power supply circuit

Supply voltage range

Terminals

X2, X3 and X4

U_B

20 ... 30 V DC

Supply current

I_B

120 mA

Supply current (4 channels)

approx.. 70 mA

Supply current (2 channels)

approx.. 60 mA

Supply current (1 channel)

approx.. 50 mA

max. r.m.s. AC or DC voltage

U_m

253 V

Signal input circuit

max. rated voltage

Terminals

X1 and X5

U_B

9 V

max. rated current

I_B

50 mA

max. r.m.s. AC or DC voltage

U_m

253 V

Intrinsically safe data- and supply circuits, signal output circuit

Type of protection

Terminals

X7, X8, X9, X10, X11, X12, X13, X14

Maximum output voltage

U_o

[Ex ib Gb] IIC, [Ex ib Db] IIIC

Maximum output current

I_o

142.4 mA

Maximum output power

P_o

130.6 mW

Maximum external capacitance

C_o

100 μ F ($L_o = 0$ mH)

Maximum external inductance

L_o

1.3 mH



IECEx Certificate of Conformity

Certificate No.: IECEx IBE 12.0021

Date of Issue: 2013-08-09

Issue No.: 1

Page 5 of 5

DETAILS OF CERTIFICATE CHANGES (for issues 1 and above):

Extension of lower limit of ambient temperature range