



中国国家强制性产品认证证书



证书编号: 2020322303002717

认证委托人名称: 博太科防爆设备(上海)有限公司
 认证委托人地址: 上海市闵行区浦江高科技园F区新骏环路188号7号楼101、401
 生产者名称: BARTEC GmbH
 生产者地址: Max-Eyth-Str. 16 97980 Bad Mergentheim Germany
 生产企业名称: BARTEC GmbH
 企业地址: Max-Eyth-Str. 16 97980 Bad Mergentheim Germany

产品名称: 防爆聚酯接线盒
 系列、规格、型号: 07-510 系列
 标准: GB 3836.1-2010、GB 3836.3-2010、GB 3836.4-2010、
 GB 12476.1-2013、GB 12476.5-2013

上述产品符合强制性产品认证实施规则 CNCA-C23-01:2019 的要求, 特发此证。

发证日期: 2020年10月7日 有效期至: 2025年10月6日

首次发证日期: 2020年10月7日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书的相关信息可通过国家认监委网站 www.cnca.gov.cn 查询



批准:



上海仪器仪表自控系统检验测试所有限公司



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION



CERTIFICATE NO: 2020322303002717

APPLICANT: BARTEC Explosion Proof Appliances (Shanghai) Co., Ltd.
ADDRESS: New Building 7, 101、401 No. 188, Xinjun Ring Road,Pujiang
 Hi-Tech Park, Minhang District,Shanghai China

MANUFACTURER: BARTEC GmbH
ADDRESS: Max-Eyth-Str. 16 97980 Bad Mergentheim Germany

FACTORY: BARTEC GmbH
ADDRESS: Max-Eyth-Str. 16 97980 Bad Mergentheim Germany

PRODUCTNAME: Junction Box
SERIES,SPECIFICATION,MODEL: 07-510 series
STANDARDS: GB 3836.1-2010、 GB 3836.3-2010、 GB 3836.4-2010、
 GB 12476.1-2013、 GB 12476.5-2013

This is to certify that the above mentioned product(s)complies with the requirements of implementation rules for compulsory certification (REFNO. CNCA-C23-01:2019).

Valid from:October 7, 2020

Valid until: October 6, 2025

Date of original certification:October 7, 2020

The validity of this certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

This certificate is available through CNCA’s website: www.cnca.gov.cn



APPROVAL:

Xu JianPing



Shanghai Inspection and Testing Institute of Instruments and Automation Systems Co., Ltd.

<http://www.sitifias.com.cn>

Building 9,103 Cao Bao Road, Shanghai 200233,China

Tel: +86 21 64510844

S 0001785



中国国家强制性产品认证证书



SITIAs
Worldwide Access

证书编号: 2020322303002717

附件

产品名称: 防爆聚酯接线盒

型号规格: 07-510 a - b c d, 其中

a 代表箱体类型, 可选代码为: 3, 5, 6, 7

b 代表箱体长度, 可选代码为: 080, 110, 160, 190, 122, 220, 260, 360, 560, 255, 400

c 代表箱体宽度, 可选代码为: 0/75, 1/20, 1/60, 2/50, 4/05

d 代表箱体高度, 可选代码为: 75, 55, 90, 120, 160, 165

防爆标志: Ex e ia IIC T5/T6, Ex e ia IIC T5/T6 Ex tD A21 IP66 T80°C/T95°C

电气参数: 最大额定电压1100V, 最大额定电流500A。

批 准:



上海仪器仪表自控系统检验测试所有限公司