

UK Type Examination Certificate CML 22UKEX3259X Issue 0

United Kingdom Conformity Assessment

- 1 Product or Protective System Intended for use in Potentially Explosive Atmospheres UKSI 2016:1107 (as amended) – Schedule 3A, Part 1
- 2 Equipment **ComEx Control and Indicating Station, Type 07-352*-*******
- 3 Manufacturer **BARTEC GmbH**
- 4 Address **Max-Eyth-Straße 16
97980 Bad Mergentheim
Germany**

5 The equipment is specified in the description of this certificate and the documents to which it refers.

6 Eurofins E&E CML Limited, Newport Business Park, New Port Road, Ellesmere Port, CH65 4LZ, United Kingdom, Approved Body Number 2503, in accordance with Regulation 42 of the Equipment and Protective Systems Intended for Use in Potentially Explosive Atmospheres Regulations 2016, UKSI 2016:1107 (as amended), certifies that this equipment has been found to comply with the Essential Health and Safety Requirements relating to the design and construction of equipment intended for use in potentially explosive atmospheres given in Schedule 1 of the Regulations.

The examination and test results are recorded in the confidential reports listed in Section 12.

7 If an 'X' suffix appears after the certificate number, it indicates that the equipment is subject to specific conditions of use (affecting correct installation or safe use). These are specified in Section 14.


8 This UK Type Examination certificate relates only to the design and construction of the specified equipment. Further requirements of the Regulations apply to the manufacturing process and supply of the product. These are not covered by this certificate.

9 Compliance with the Essential Health and Safety Requirements, with the exception of those listed in the confidential report, has been demonstrated through compliance with the following documents:

EN IEC 60079-0:2018	EN 60079-1:2014	EN IEC 60079-7:2015+A1:2018 (*)
EN 60079-11:2012 (**)	EN 60079-31:2014 (*)	


10 The equipment shall be marked with the following:

(*) 07-3521-..., 07-3522-... and 07-3523-... (**) 07-3524-..., 07-3525-... and 07-3526-...



Ex db eb IIC T6 Gb

Ex tb IIIC T80°C Db



Ex db ia IIC T6 Gb





CML 22UKEX3259X
Issue 0

1st & 2nd slots or 2nd & 3rd slots – double-slot actuators & modules combinations

* * * Actuator	Module
G * * * * * Selector switch for control module type 07-3400-G***/*	Control switch module type 07-3332-1***/*
F * * 1 * * Selector switch large type 07-3400-F***/*	Switch module type 07-3322-1100/*
F * * 2 * *	Switch module type 07-3322-1200/*
F * * 4 * *	Switch module type 07-3322-1400/*
F * * 5 * *	Switch module type 07-3322-1110/*
F * * 6 * *	Switch module type 07-3322-1210/*
F * * 7 * *	Switch module type 07-3322-1410/*
A * * V * * Push button type 07-3400-A***/*	Switch module type 07-3382-****/*
E * * V * * Key selector switch type 07-3400-E***/*	
F * * V * * Selector switch large type 07-3400-F***/*	
N * * V * * Emergency stop pull to release type 07-3400-N***/*	
P * * V * * Mushroom push button type 07-3400-P***/*	
S * * V * * Selector switch type 07-3400-S***/*	

1st, 2nd and 3rd slot – single-slot actuators & modules combinations

* * * Actuator	Module
0 * 0 without actuator	without module
B * 0 Blind plug type 07-3400-B***/*	
A * * Push button type 07-3400-A***/*	Switch module type 07-3322-1**0/*
C * * Double push button type 07-3400-C***/*	
E * * Key selector switch type 07-3400-E***/*	
N * * Emergency stop pull to release type 07-3400-N***/*	
P * * Mushroom push button type 07-3400-P***/*	
R * * Emergency stop twist to release type 07-3400-R***/*	
S * * Selector switch type 07-3400-S***/*	
D * * Potentiometer type 07-3400-D***/*	Potentiometer module type 07-3372-1D*0/**** d)
L * * Pilot light type 07-3400-L***/*	Illuminated indicator module type 07-3352-11*0/**** d) or type 07-3352-14*0/**** c)
T * A Illuminated push button type 07-3400-T***/*	Illuminated push button module type 07-3362-17*0/**** d) or type 07-3362-15*0/**** c)
T * B	Illuminated push button module type 07-3362-18*0/**** d) or type 07-3362-16*0/**** c)
T * C	Illuminated push button module type 07-3362-11*0/**** d)
T * D	Illuminated push button module type 07-3362-12*0/**** d)

* - manufacturer and customer specific suffixes (number or letter) without influence on the explosion protection

- a) Only for type 07-352, followed by 2, 3, 5 or 6, followed by additional suffixes.
- b) Only for type 07-352, followed by 3 or 6, followed by additional suffixes.
- c) Only for type 07-352, followed by 4, 5 or 6, followed by additional suffixes.
- d) Only for type 07-352, followed by 1, 2 or 3, followed by additional suffixes.



CML 22UKEX3259X
Issue 0

12 Certificate history and evaluation reports

Issue	Date	Associated report	Notes
0	08 Nov 2023	R14623A/00	Issue of Prime Certification

Note: Drawings that describe the equipment are listed in the Annex.

13 Conditions of Manufacture

The following conditions are required of the manufacturing process for compliance with the certification.

- i. Where the product incorporates certified parts or safety critical components, the manufacturer of the product defined on this certificate shall continually monitor these parts/components for any modifications introduced by the manufacturer(s) of these constituent parts. If the manufacturer of any constituent part introduces any changes which affect the compliance of the certified product that is the subject of this certificate, the manufacturer is required to have this certificate updated.
- ii. All safety critical Ex Components must be installed in accordance with their schedule of limitations.
- iii. The manufacturer shall ensure that the user is provided with the entity parameters of all intrinsically safe modules supplied as part of the equipment.

14 Specific Conditions of Use

The following conditions relate to safe installation and/or use of the equipment.

- i. The ComEx control and indicating station shall be installed, so it will be protected against electrostatic charging. The metal entry devices shall be grounded.
- ii. The technical data of separately certified cable glands and blanking element acc. to manufacturer specifications shall be observed.
- iii. The wiring internal to equipment which might come into contact with a conductive part shall be mechanically protected, secured, or routed to avoid insulation damage.
- iv. The connection cables shall have a minimum service temperature below or equal to the minimum ambient temperature for the ComEx control and indicating station and a maximum service temperature above or equal to 80 °C.
- v. The maximum permissible currents must not exceed the values according to the arrangement tables corresponding maximum ambient temperatures and the configurations of the ComEx control and indicating station.
- vi. Each terminal of the module is limited to one conductor per clamping unit.
- vii. The values U_0 , I_0 , C_0 and L_0 of an approved Intrinsically Safe Apparatus connected to the ComEx control and indicating station must not exceed the permissible maximum values specified in IEC 60079-11 / EN 60079-11 and IEC 60079-25 / EN 60079-25, if applicable, for the zone(s) and group(s) of the corresponding hazardous areas of the location of the ComEx control and indicating station.



CML 22UKEX3259X
Issue 0

- viii. The wiring internal to the equipment shall be carried out in such a way that a distance between the bare conducting parts of a cable lug mounted on the feed-through terminal for earthing and any other terminals is at least 10 mm.
- ix. The ComEx control and indicating station type 07-3521-..., 07-3522-... or 07-3523-... must not be connected with a sleeve fixing to the ComEx control and indicating station type 07-3524-..., 07-3525-... or 07-3526-... equipped with conduit adapters
- x. The minimum ambient temperature for the ComEx control and indicating station shall be above or equal to the minimum ambient temperature for the separately certified cable glands and blanking elements, but above or equal to -55 °C. The maximum ambient temperature for the ComEx control and indicating station shall be below or equal to 40 °C resp. 60 °C.
- xi. The intrinsically safe circuits are galvanically isolated from each other in accordance with IEC / EN 60079-11.
- xii. The user shall ensure that all wiring to intrinsically safe modules is installed in accordance with the requirements of IEC / EN 60079-14 Clause 16.

Certificate Annex



Certificate Number CML 22UKEX3259X
Equipment ComEx Control and Indicating Station,
 Type 07-352*-*****
Manufacturer BARTEC GmbH

The following documents describe the equipment defined in this certificate:

Issue 0

Document No	Sheets	Rev	Approved date	Title
01-3520-6A0001	1 of 1	-	08 Nov 2023	Minimum content of Marking ComEx Control and indicating station type 07-3521-***** , 07-3522-***** und 07-3523-*****
01-3520-6A0002	1 of 1	-	08 Nov 2023	Minimum content of Marking ComEx Control and indicating station type 07-3524-***** , 07-3525-***** und 07-3526-*****
01-3520-6B0001	1 to 33	-	08 Nov 2023	Description ComEx control and indicating station type 07-352*-*****
01-3520-650001	1 to 2	-	08 Nov 2023	ComEx control and indicating station type 07-352*-*****
01-3520-650001-BOM	1 to 2	-	08 Nov 2023	ComEx control and indicating station type 07-352*-*****
01-3520-650003	1 of 1	0	08 Nov 2023	Control and indicating station type 07-352*-*****
01-3520-650005	1 of 1	-	08 Nov 2023	Control drawing type 07-352*-*****
01-3530-650001	1 to 3	-	08 Nov 2023	Enclosure type 07-353*-....
01-3530-650001-BOM	1 to 2	-	08 Nov 2023	Enclosure type 07-353*-....
01-3530-650002	1 of 1	-	08 Nov 2023	Enclosure type 07-353*-....