

# CERTIFICATE OF COMPLIANCE

**Certificate Number** E486512  
**Report Reference** E486512-20190426  
**Date** 2021-November-18

**Issued to:** BARTEC F.N. S.R.L.  
Via Mario Pagano 3  
Trezzano S/Naviglio MI 20090 IT

**This is to certify that  
representative samples of**

**INDUSTRIAL CONTROL PANELS AND ASSEMBLIES  
FOR USE IN HAZARDOUS LOCATIONS**

See Addendum Page for Product Designation(s).

Have been investigated by UL in accordance with the  
Standard(s) indicated on this Certificate.

**Standard(s) for Safety:**

UL 1203 - EXPLOSION-PROOF AND DUST-IGNITION-  
PROOF ELECTRICAL EQUIPMENT FOR USE IN  
HAZARDOUS (CLASSIFIED) LOCATIONS

CSA C22.2 NO. 30-M1986 - EXPLOSION-PROOF  
ENCLOSURES FOR USE IN CLASS I HAZARDOUS  
LOCATIONS

UL 698A - INDUSTRIAL CONTROL PANELS RELATING  
TO HAZARDOUS (CLASSIFIED) LOCATIONS

CSA C22.2 NO. 157-92 - INTRINSICALLY SAFE AND  
NON-INCENDIVE EQUIPMENT FOR USE IN  
HAZARDOUS LOCATIONS

**Additional Information:**

See the UL Online Certifications Directory at  
<https://iq.ulprospector.com> for additional information

This Certificate of Compliance does not provide authorization to apply the UL Mark. Only the UL Follow-Up Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>




# CERTIFICATE OF COMPLIANCE

**Certificate Number** E486512  
**Report Reference** E486512-20190426  
**Date** 2021-November-18

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements

Industrial Control Panels for Use in Class I, Division 1, Groups B, C and D Hazardous Locations.

May be provided with intrinsically safe circuit extensions for use in Class I, Division 1, Groups A, B, C and D; Class II, Division 1, Groups E, F and G; and Class III Hazardous Locations.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

